



## QUESTIONS & RESPONSES #02

RFP or RFQ / TITLE 071447 | Lower Wapato Creek Habitat Project 2021

CONTACT Heather Shadko, PROCUREMENT

EMAIL [procurement@portoftacoma.com](mailto:procurement@portoftacoma.com)

PHONE NUMBER 253-428-8697

SUBMITTAL DUE DATE June 23, 2021 @2:00PM (PST)

Q&A ISSUE DATE Tuesday, June 15, 2021

PROPOSER QUESTIONS	PORT RESPONSES	RFP/ RFQ Section
Why there is a bridge that appears completely unrelated to the project as well as power line modifications that are also best addressed with a separate contracts?	<a href="#">The Project scope is as listed as One (1) Contract to include all components of work.</a>	
Does the pipe need insulation going through the pipe supports?	<a href="#">No insulation will be required at the supports.</a>	
Do the expansion joints need to be insulated?	<a href="#">No insulation will be required at the expansion joints.</a>	