



QUESTIONS & RESPONSES #01

RFP or RFQ / TITLE 071547 | Administration Building Restroom Repairs

CONTACT Heather Shadko, PROCUREMENT

EMAIL procurement@portoftacoma.com

PHONE NUMBER 253-428-8697

SUBMITTAL DUE DATE September 8, 2021 @ 11:00 AM (PST)

Q&A ISSUE DATE August 31, 2021

PROPOSER QUESTIONS	PORT RESPONSES	RFP/ RFQ Section
Can I get the make and model of the fire alarm system?	Farenhyt Series, Honeywell Model IFP-300	
Also wondering if I have a TWIC card will I be considered an escort for personnel who don't and if not what is the charge for an escort?	You can be considered an escort for non TWIC personnel, however, escorts cannot perform work. Their duty is to monitor those that do not have a TWIC. Vendors hire their own escorts, the Port is not involved in that process.	