

## QUESTIONS & RESPONSES #03

RFP or RFQ / TITLE 071514 | SIM Yard Charging Stations

CONTACT Heather Shadko, PROCUREMENT

EMAIL <u>procurement@portoftacoma.com</u>

PHONE NUMBER 253-428-8697

SUBMITTAL DUE DATE September 21,2021 @ 11:00 AM (PST)

Q&A ISSUE DATE September 9, 2021

PROPOSER QUESTIONS	PORT RESPONSES	RFP/ RFQ Section
Is the project just for the installation of the truck charging stations? Or will the Port be looking to also purchase the chargers?	The scope of this project does include installation of the charging stations. The scope does not include purchase of the charging stations.  Charging stations will be procured by the current SIM Yard tenant. The Port will then provide the charging stations to the Contractor and the Contractor will be responsible for their installation. Refer to Section 01 64 00 for relevant details.	
While going through the project document pages, it appears that Specs Section 267119 is missing according to the Table of Contents.	Section 26 71 19 is not included with this Contract 071514 project manual. The Table of Contents has been updated to remove the reference to Section 26 71 19. Refer to Addendum 01.	
On the general notes of the electrical plans it requires the contractor to provide UL testing on all non UL rated assemblies. The charging stations are indicated to be provided by the "Tenant", can you please confirm the charging stations being provided are UL rated?	Contractor shall provide all equipment UL-listed wherever applicable per the project specifications.  The Owner-furnished charging stations are not UL-listed. Per General Note 4 on Sheet E1.0, Contractor shall provide field safety certification of the charging stations by a Department of Labor and Industries approved firm.	