

People. Partnership. Performance.

P.O. Box 1837 Tacoma, WA 98401-1837 www.portoftacoma.com

October 15, 2015

TO: PLANHOLDERS

SUBJECT: TOTE ADMINISTRATION BUILDING HVAC UPGRADE

PROJECT NO. 098034 CONTRACT NO. 070083

ADDENDUM NUMBER ONE

This addendum is issued to amend the following:

SPECIFICATIONS

A. SECTION 23 33 00 - AIR DUCT ACCESSORIES - SUBSTITUTION REQUEST

1. Section 2.04 - Air Balance (Fire Dampers) is **NOT** approved as noted in Substitution request (Attachment A)

B. SECTION 23 37 13 - DIFFUSERS, REGISTERS AND GRILLS- SUBSTITUTION REQUEST

1. Section 2.01-2.02 - ADD Tuttle & Bailey (Air System Components) as an approved Substitution (Attachment B)

DRAWINGS

A. DRAWING SHEET E9 - ONE-LINE DIAGRAM

1. REPLACE with revised Drawing Sheet E9 (Attachment C)

Receipt for this addendum shall be indicated in the space provided in Section 00 41 00, Bid Form.

END OF SECTION

ATTACHMENT A - Air Duct Accessories - Substitution Request - Not Approved

ATTACHMENT B - Diffusers, Registers and Grills- Substitution Request - Approved

ATTACHMENT C - Revised Drawing Sheet E9 - One-Line Diagram

Project No. 098034 Contract No. 070083 00 91 11.01 - 1

DIVISION 00 - PROCUREMENT AND CONTRACTING REQUIREMENTS SECTION 00 43 25 - SUBSTITUTION REQUEST FORM - DURING BIDDING

Project Title	TOTE (DOWN) WHAT IS	0.0	
Submitted Rv	TOTE ADMIN HUAC U	PGKACES Project No.	E3905
Prime/Sub/Supplier:	2,000 0,000 0,000 0,000 0,000	Contract No.	
		Date:	10-6-15
Specification Title:	AIR DUCT AGCESSORIES	Section No.	_ 23 33 00
	FIRE DAMPERS	TO THE PARTY CONTRACTOR OF THE PARTY OF THE	2.04
Proposed Substitu	ution: AIR BALAUCE		
Trade Name:	MESTEK	Model No.:	119
Manufacturer:			,
Address:	450 RIVERSIDE DR. WYALUSII	วน ชิล 18853 Phone No.:	570 746 1888
Attached data inclines	product description, specification of the request; applicable portion	50 500 W 00 00	
Attached data also inclu	ides a description of changes to tallation.	the Contract Documents the	itified,
require for its proper inst	allation.	are counted becamens that	tine proposed substitution will
 Same warranty will b Same maintenance s Proposed substitution 	on has been fully investigated a be furnished for proposed substit service and source of replacement in will have no adverse effect on in does not affect dimensions and de for changes to building designation.	ution as for specified product ent parts, as applicable, is ava other trades and will not affec	ilable. ct or delay progress schedule
Submitted By: JERR	ey GADDIS		
Signed By:	y soft	Firm: FM WAC SA	EC
Address: 4610	200th ST SW SUITE	<u> </u>	<u>«C)</u>
	00000 WA 98036		
Telephone: 206-3	14-022a	Email: JERRY & FMHV	N SALES
Supporting Data Attached			
☐ Drawings ☐ Product	Data ☐ Samples ☐ Tests	☐ Reports ☐ Other	
ENGINEER'S REVIEW AI	ND ACTION		
☐ Substitution approved			0.045
☐ Substitution approved a ☑ Substitution rejected - U	In account	cordance with 23 33 00 gide dynamic rated fire o	- 2.04B Iamner
☐ Substitution Request re	ceived too late - Use specified r	naterials.	
	(se)		10.09.15
Project Form - 00 43 25		Date:	Page 1

MODEL 119

4%" Deep • 1½ Hour • Vertical or Horizontal Mount • Static Rated • Fire Damper

STANDARD MATERIALS AND CONSTRUCTION

FRAME: 22-GA galvanized steel, one-piece rollformed

BLADE: 22-GA galvanized steel, curtain type FUSIBLE LINK: UL-Listed 165°F; Replaceable

CLOSURE SPRINGS: Horizontal Models - Heat-treated Type 301 stainless

steel constant force coiled negator type

FINISH: Mill

OPTIONS

212°F Replaceable Fusible Link

Factory-Supplied Sleeves (20-GA through 10-GA)

Type 304 Stainless Steel Construction PK1202 Position Indicator Switch

B-Pan, Round, Oval, or Square Transitions

Multiple Panel Unit Assembly **Tab-Lock Retaining Angles**

Perimeter Flange

Pull Ring

NOTES

- 1. "A" width and "B" height are opening dimensions. Dampers are provided
- 2. Unassembled multiple units do not include mullions.
- 3. See SI-SSFD for information regarding Stainless Steel Fire Dampers.

UNDERWRITERS LABORATORIES, INC.®

CLASSIFIED STATIC FIRE DAMPERS FIRE RESISTANCE RATING 11/2 HR.

abi air balance inc.


FILE #R4708


This fire damper meets the construction and performance requirements of:

- Underwriters Laboratories Inc. Standard 555
- · National Fire Protection Association Standard 80 and 90A
- · ICC's International Building Code
- California State Fire Marshal Listing #3225-1328:100
- · Underwriters Laboratories Inc. Approved for dual direction airflow and static closure conditions.
- · Underwriters Laboratories Inc. Classified for use in fire resistive ratings of less than 3 hours.

DAMPER SIZES

Orientation	rientation Hor & Ver		Horizontal (floor)		Vertical (wall)		
Panels	Min Panel	Max Single Panel	Max Assy Panel	Max Single Panel	Max Assy Panel		
119A	4"W x 4"H	48"W x 48"H	102"W x 48"W (36"W x 48"H each section)	60"W x 60"H	120"W x 120"W (40"W x 60"H each section)		
119B	4"W x 3"H (duct) 4"W x 5"H (frame)	48"W x 43"H (duct) (48"W x 48"H frame)	102"W x 43"H (duct) (102"W x 48"H frame) (36"W x 43"H each section duct)	60"W x 55"H (duct) (60"W x 60"H frame)	120"W x 115"H (duct) (120"W x 120"H frame) (40"W x 60"H each section duct)		
119C	4"W x 4"H (duct) (6"W x 7"H frame)	46"W x 42"H (duct) (48"W x 48"H frame)	100"W x 42"H (duct) (102"W x 48"H frame)	58"W x 54"H (duct) (60"W x 60"H frame)	118"W x 114"H (duct) (120"W x 120"H frame)		








DIVISION 00 - PROCUREMENT AND CONTRACTING REQUIREMENTS SECTION 00 43 25 - SUBSTITUTION REQUEST FORM - DURING BIDDING

Project Title TOTE ADMIN HVAC OPE Submitted By: FM HVAC SALES	
Prime/Sub/Supplier:	
Specification Title: ptffcsets, Remisiting 1 (Right Description:	Paragraph: 2.01 - 2.02
Proposed Substitution: TUTILE & BAILEY Trade Name: AIR SYSTEM COMPOUNTS Manufacturer:	
Address: 140\ \(\omega\). PLANO ROAD RICHARS Attached data includes product description, specification adequate for evaluation of the request; applicable portion	S. drawings, photographs, and performance and test data
 Same warranty will be furnished for proposed substitution Same maintenance service and source of replaceme Proposed substitution will have no adverse effect on a proposed substitution does not affect dimensions and 	nt parts, as applicable, is available. other trades and will not affect or delay progress schedule.
Submitted By: JERRY GADDIS Signed By: Juy May: Address: 4610 200th ST SW SUME LYWWOOD WA 98036 Telephone: 206-374-0222 Supporting Data Attached:	Firm: FM WAX SAVES E Email: JERRY @ FMHVACSAVES
☐ Drawings ☐ Product Data ☐ Samples ☐ Tests	☐ Reports ☐ Other
ENGINEER'S REVIEW AND ACTION Substitution approved Substitution approved as noted Substitution rejected - Use specified materials. Substitution Request received too late - Use specified in	naterials.
Signed by: Project Form - 00 43 25	Date: 10.09.15
Froject Form - 00 43 25	Page 1

CEILING DIFFUSERS

Modular - Adjustable SQD & AQD





SQD

STEEL

ALUMINUM

The SQD (steel), AQD (aluminum) diffusers are designed and built specifically for modularity and ease in air pattern adjustability. With the SQD & AQD, a single diffuser provides a multitude of air patterns, which can be easily set in the field to meet each specific space requirement.

The key to the SQD & AQD diffuser lies in its four individual louver modules, which are completely removable and can be easily rotated in various directions to provide a multitude of pattern arrangements. The diffusers can be easily set in the field because the modules are adjustable without the use of tools.

The louver modules are specially designed for low pressure loss and minimal see-through at all module settings. The SQD & AQD diffusers can be set in a 4-way, 3-way, 2-way, or 1-way air pattern in various arrangements. They provide exceptional horizontal ceiling patterns effective for cooling applications.

FEATURES

- Several different air patterns can be achieved with a single diffuser
- Four individual louver modules can be set in a 4-way, 3-way, 2-way, or 1-way air pattern and are adjustable without the use of tools
- Louver modules can be removed for access to the mounting margin and neck damper
- · Standard finish is white paint (WH)

Neck Size	Available Sizes Surface Lay-in T-Bar				
(in.)	F7. 50 4 45 3	unt SB	de verb	4 Pane TG	22.1
6x6	Х	Х	Х	Х	Х
8X8	Х	Х	X	X	X
10X10	Х	Х	Х	Х	Х
12X12	Х	Х	X	Х	Х
14X14	Х	Х	Х	Х	Х
16X16	Х	Х	Х	Х	Х
18X18	Х	Х	Х	Х	X
20X20	Х	Х			
22X22	Х	Х			
24X24	Х	Х			




GRID CORE GRILLES & REGISTERS

CRE, CR, SCRE Series





Product available in one inch increments of width and height. Sizes greater than 48x48 are supplied in multiple sections.



CRE500

EXTRUDED ALUMINUM

STEEL/ALUMINUM


Series CRE, CR and SCRE eggcrate grilles have grid cores capable of transferring or returning high air volumes at minimum pressure requirements. They match grid louvers in appearance on luminaries and fit both Lay-in T-Bar openings in suspended grid ceilings and overlap openings (surface mount) in hard ceilings and walls. The CRE and CR series have aluminum margins with aluminum grid cores. The SCRE series has a steel margin with aluminum grid core and can be used in fire rated ceiling applications.

FEATURES


- 1-1/4" nominal overlap margin
- Furnished with countersunk screw holes and mounting screws
- Aluminum construction (CRE and CR series)
- Steel margin with aluminum grid core (SCRE series)
- CR series with U-frame can accommodate damper
- Three grid core styles: 1/2" x 1/2"x 1/2"(500), 1/2" x 1/2" x 1"(510), 1" x 1" x 1"(1000)
- · Standard finish is White (WH)

ACCESSORIES

- Optional opposed blade damper (SOBD steel, AOBD – aluminum) is factory mounted and screwdriver operated from face of grille
- Optional aluminum mounting frame (A45) available for use in plaster applications to facilitate grille removal
- Optional steel mounting frame (45) available for use in plaster applications to facilitate grille removal (SCRE)




CRE1000



CR1000U





Port of a Co. BOX 1837 TACOMA, WAS

∴ O $N \circ$ ∶<্ ত

MARK

FOTE ADMINISTRATION BUILDING HVAC SYSTEM REPLACEMENT ONE-LINE DIAGRAM