

# Question & Answer #2



People. Partnership. Performance.

P.O. Box 1837  
Tacoma, WA 98401-1837  
www.portoftacoma.com

## 401 ALEXANDER BUILDING 9407 ROOF REPLACEMENT AND BUILDING UPGRADES MASTER ID 091362 | CONTRACT NO. 070129

### 1. BIDDER QUESTION

I asked in the pre-bid meeting about the skylights and whether they needed the screens in the protection spec. They both meet the same OSHA requirement.

### RESPONSE

Bidders are to provide the screens as specified in 08 67 00.

Based on coordination with the local supplier, the size of these units warrants the extra safety measure.

END OF Q&A