

Port of Tacoma Invitation to Bid # 71985

**Addendum # 2**

**Date 3/03/2016**

The following is additional information regarding **ITB-71985** titled **Glulam & Structural Lumber** released on 3/2/2016. **The due date and time for responses remains as 3/11/2016 @ 2:00PM PST.** This addendum includes both questions from prospective bidders and the Port's answers, and revisions to the ITB. This addendum is hereby made part of the ITB and therefore, the information contained herein shall be taken into consideration when preparing and submitting a bid.

Item #	Date Received	Date Answered	Vendor's Question	Port's Answer	ITB Revisions
1	3/2/16	3/3/16	Will you be accepting pricing excluding "setup" as outlined at the top of page 11?	See our revision.	ITB 71985 Attachment A – Offer Sheet is updated to:  FREIGHT: All freight and delivery costs are to be included in the cost of Lumber. (Note: Gr is the abbreviation for grade).
2	3/3/16	3/3/16	24F-E13 is not a good spec for Glulam's	See comments at item 4 below	
3	3/3/16	3/3/16	Are the hex bolts plain or galvanized?	Galvanized	
4	3/3/16	3/3/16	I have reached out to a couple of lam plants and no one will quote 24F-E13  - Are we able to use Douglas fir 24F-V8 in lieu of 24F-E13?  - Are you requiring <b>INDUSTRIAL</b> or <b>ARCHITECTURAL</b> grade on the glu-lams?	Yes, substitution of 24f-v8 is acceptable.  Glulams to be industrial grade.	
5	3/3/16	3/3/16	On the Douglas Fir Select Structural materials - Do you want <b>S4S</b> or <b>ROUGH</b> ?	S4S	
6	3/3/16	3/3/16			Attachment G, SK-1 added to the ITB 71985

Port of Tacoma Invitation to Bid # 71985

**Addendum # 2**

**Date 3/03/2016**

7	3/3/16	3/3/16	Does the bidder need to bid all items on the list, or can we bid only the lumber & Glulams, and not bid on the "hardware"?	All bid items need to be bid on including the hardware.	
8					
9					
10					
11					
12					
13					
14					
15					
16					
17					
18					
19					
20					