



## QUESTIONS & RESPONSES o

RFQ or RFP / TITLE 070735 - MAINTENANCE MEZZANINE AND SHED HEATING

CONTACT Juli Tuson, Procurement

EMAIL [procurement@portoftacoma.com](mailto:procurement@portoftacoma.com)

PHONE NUMBER 253-383-9436

BID DUE DATE January 31, 2018 @ 2:00 PM PST

DATE ISSUED January 16, 2018

1	PROPOSER QUESTIONS	PORT RESPONSES
	How are Commissioning services to meet the Washington State energy code being procured on this project?	The lighting control for the project is limited only to testing the (4) Ceiling Occupancy Sensors. The Port and the electrical engineer will inspect and test the lighting controls after installation.

RFP/RFO Section/Pg