



QUESTIONS & RESPONSES #02

BID / TITLE 070929 | NIM Tower 4th Floor Renovations

CONTACT Heather Shadko, PROCUREMENT

EMAIL procurement@portoftacoma.com

PHONE NUMBER 253-428-8697

SUBMITTAL DUE DATE March 13, 2019 @ 3:00 PM (PST)

Q&A ISSUE DATE March 4, 2019

PROPOSER QUESTIONS	PORT RESPONSES	RFP/ RFQ Section
Do you see any need for a professional moving company to move existing furniture and desks out of the way, and then set them back up upon completion? Any need for temperature-controlled storage of your office furniture during renovations?	No. Port Maintenance will relocate and store existing furniture, as needed.	
It does not appear G.E., Maytag, or Uline make undercounter refrigerators in the listed acceptable storage capacity and size. If possible can we confirm the sizes listed or acceptable list?	<p>To confirm:</p> <ol style="list-style-type: none"> 1. The refrigeration compartment size should be approximately 5 cubic feet. 2. The freezer volume size should be approximately 0.5 cubic feet. 3. The unit height should be approximately 34" and capable of fitting under the countertop which is 36" high on the top surface. 4. The unit depth should be approximately 24" deep. 5. The unit width should be approximately 25" wide. <p>Should any bidder desire to submit a pre-bid substitution request, please adhere to guidance contained in Section 00 26 00.</p>	