



POINT TABLE			
POINT #	NORTHING	EASTING	DESC
B1	710969.06	1164454.96	MWS 8X20 – NORTH CORNER
B2	710962.51	1164447.13	MWS 8X24 – NORTH CORNER
B3	710956.10	1164439.46	MWS 8X24 – NORTH CORNER
B4	710946.89	1164461.50	MWS 8X20 – SOUTH CORNER
B5	710937.56	1164456.26	MWS 8X24 – SOUTH CORNER
B6	710931.15	1164448.59	MWS 8X24 – SOUTH CORNER
B7	710946.05	1164474.21	MWS 8X20 – NORTH CORNER
B8	710939.50	1164466.38	MWS 8X24 – NORTH CORNER
B9	710933.09	1164458.71	MWS 8X24 – NORTH CORNER
B10	710923.88	1164480.75	MWS 8X20 – SOUTH CORNER
B11	710914.55	1164475.51	MWS 8X24 – SOUTH CORNER
B12	710908.14	1164467.84	MWS 8X24 – SOUTH CORNER
B13	710938.33	1164432.78	HYDRODYNAMIC SEPARATOR – CENTER
B14	710909.41	1164453.16	VALVE VAULT – WEST CORNER
B15	710909.69	1164465.96	VALVE VAULT – EAST CORNER
B16	710896.70	1164462.18	PUMP STA – WEST CORNER
B17	710901.86	1164483.93	PUMP STA – EAST CORNER
B18	710887.06	1164467.43	BOLLARD
B19	710912.62	1164498.20	BOLLARD
B20	710918.21	1164498.92	BOLLARD
B21	710973.60	1164452.92	BOLLARD
B22	710974.16	1164447.09	BOLLARD
B23	710948.60	1164416.32	BOLLARD

- CONSTRUCTION NOTES:
- CONTRACTOR SHALL COORDINATE WITH OWNER AND EQUIPMENT SUPPLIERS FOR DELIVERY, INSTALLATION, AND COMMISSIONING OF OWNER-SUPPLIED EQUIPMENT, INCLUDING THE PUMPING STATIONS, HYDRODYNAMIC SEPARATORS, AND INDUSTRIAL MEDIA MODULAR WETLAND TREATMENT SYSTEMS.
 - SEE MECHANICAL AND ELECTRICAL SHEETS FOR WORK SCOPE DELINEATION DETAILS.
 - PRIOR TO COMMISSIONING OF TREATMENT SYSTEMS, CONTRACTOR SHALL CLEAN EXISTING STORM DRAIN STRUCTURES UPSTREAM OF TREATMENT SYSTEMS TO END OF PIPE BY FLUSHING ONE PIPE VOLUME MINIMUM, AND IN ACCORDANCE WITH WSDOT 7-07.
 - SEE SHEET G07 FOR WORK AND STAGING AREA LIMITS.
 - ALL FILL MATERIAL SHALL BE COMPACTED TO 95% RELATIVE DENSITY.
 - CONTRACTOR SHALL MATCH EXISTING GRADES UNLESS SHOWN OTHERWISE.
 - COORDINATES (CO) ARE APPROXIMATE. CONTRACTOR SHALL VERIFY LOCATIONS BASED ON EXISTING CONDITIONS AND EQUIPMENT INSTALLATION REQ'TS.
 - CONTRACTOR SHALL VERIFY PIPE DIAMETERS AND MATERIAL PRIOR TO CONNECTION.
 - RESTORE PAVEMENT STRIPING AS REQUIRED.
 - RELOCATE EXISTING UTILITIES AS NECESSARY BASED ON RESULTS OF FIELD EXPLORATIONS. CONFIRM RELOCATION WITH PORT AND ENGINEER PRIOR TO PERFORMING WORK.
 - ALL JOINT, FITTINGS, AND VALVES SHALL BE RESTRAINED.
 - PREPARE SUBGRADE PER GEOTECHNICAL REPORT. SEE MECHANICAL SECTIONS FOR DETAILS.
 - CONTRACTOR TO POT HOLE PRIOR TO CONSTRUCTION AND CONFIRM MATERIAL, SIZE, HORIZONTAL AND VERTICAL LOCATIONS OF EXISTING UTILITIES.

6583
SH 12 OF 47
C02
CONT/CONS: 070664
M. ID: 201024.01
PHASE: BID SET

WEST SITCUM
STORMWATER TREATMENT
SITE PLAN - BASIN B

APPROVED: *[Signature]*
DLD JAN 2018
CHECKED BY: CIS
DATE: APR 2018
DIRECTOR ENG. DATE: 5/16/18
PRINTED BY: onderbr May 16, 2018
PORT ADDRESS: ONE SITCUM PLAZA
TACOMA, WA 98401-1837

Parametrix
ENGINEERING PLANNING ENVIRONMENTAL SCIENCES
50 WASHINGTON AVENUE, SUITE 300
BREMERTON, WA 98337
P 360.377.0014
WWW.PARAMETRIX.COM

Port of Tacoma
P.O. BOX 1887 TACOMA, WA 98401 (203385-0461)

BY: CIS
REVISION: 4
DATE: 5/16/18
APPR: SW

SEAL
STATE OF WASHINGTON
CITY OF TACOMA
PROFESSIONAL
56388
MAY 16, 2018

THIS DRAWING IS THE PROPERTY OF THE PORT OF TACOMA AND SHALL NOT BE USED ON OTHER WORK, DISCLOSED, COPIED, IN WHOLE OR IN PART, WITHOUT WRITTEN PERMISSION